



December 28, 2016

Douglas Elliman Real Estate
Lori Guilander
Box 6450
Snowmass Village, Co. 81615

ATTN: Michael Dickson

On 12/22/16, a well test was conducted on a well at Lot 51 Shield-O Road. The following information was obtained;

Well Depth----- 162'
Casing Size----- (7 x 5)"
Standing water level----- 42'
Total test time----- 4 Hours
Drawdown to ----- 59.62'
Production is ----- 15 GPM

This test was conducted with 1 Hp test pump. The well water level recovered back to 49.36' in 40 Minutes. If you have any questions please call me, Raun Samuelson at 970-945-6309.

Sincerely;

Raun E Samuelson
Samuelson Pump Co.

STANDARD BACTERIOLOGICAL WATER TEST
ASPEN CONSOLIDATED SANITATION DISTRICT
0400 SERVICE CENTER DRIVE
ASPEN, COLORADO 81611
(970) 925-7262, Ext. 109

PWS ID # _____ Sample Location 1st St Shields road
 SAMPLE TAKEN: DATE 12/27/16 TIME 12:05 pm NAME OF SUPPLY Well
 COUNTY Pitkin SAMPLER Evans CHLORINE RESIDUAL _____ MG/L
 COMMUNITY SUPPLY ROUTINE DISTRIBUTION SYSTEM SUPPLY
 NON COMMUNITY CHECK SAMPLE PROCESS WATER
 OTHER PUBLIC RAW GROUND SURFACE
 PRIVATE SPECIAL PURPOSE SAMPLE
 *NOTE: IF ALL INFORMATION IS NOT SUPPLIED, THE SAMPLE WILL BE DISCARDED.
 REMARKS: _____
 RETURN TO Summerson Pump Co
 ADDRESS PO Box 297
 CITY-STATE Glenwood Springs CO 81602
 PHONE Picasc Fax 947-9448

- SEE INSTRUCTIONS ON BACK PAGE -

SEE REVERSE FOR TIME LIMITATIONS, SAMPLING INSTRUCTIONS AND DEFINITIONS.
GPF 7/2013

Analyst DAF UNSUITABLE FOR TEST **SAC**

RESULTS	
MEMBRANE FILTER / COLILERT	
DIRECT COUNT:	<u>0</u> COLONIES
ADJUSTED COUNT:	<u>0</u> COLONIES/100ML
TOTAL COLIFORM:	<u>0</u> ABSENT PRESENT
FECAL COLIFORM:	<u>0</u> ABSENT PRESENT
MEDIA	
LTB 24	
LTB 48	
BGB	
MPN	COLIFORM/100ML
PRESENCE OF COLIFORMS INDICATE NON-COMPLIANCE WITH MINIMUM DRINKING WATER STANDARDS.	
<input checked="" type="checkbox"/> Compliance <input type="checkbox"/> Non-Compliance <input type="checkbox"/> Invalid	

DO NOT WRITE IN THIS SPACE
 RECEIVED
 DATE 12/27/16 TIME 12:42P
 DATE 12/27/16 TIME 12:42P IN TEST